



Green Valley Special Utility District  
529 S Center St, P.O. Box 99  
Marion, Texas 78124  
Telephone: 830.914.2330  
Fax: 830.420.4138

---

February 24, 2023

Green Valley Special Utility District Customers,

The Green Valley SUD water system, PWS ID# 0940020, has violated the reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This violation occurred in the monitoring period: Third Quarter of 2022.

Testing and monitoring was completed and verified safe drinking water, however the online submittal of the report was not transmitted properly to the TCEQ.

We are taking the following actions to address this issue:

- Reports are verified to be submitted by two members of Green Valley SUD staff.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Philip DeFrancesco at (830) 914-2330.